

CERTIFICATE OF CONSTANCY OF PERFORMANCE

1116-CPR-116-2

In compliance with Regulation (EU) N°305/2011 of 09/03/2011 laying down harmonised conditions for the marketing of construction products (Construction Products Regulation – CPR), it has been stated that the construction products below:

DS-PDSMK-S-WE - HIKVISION (Smoke alarm device)

Normal power source:	Internal to the device by lithium battery of 3V (10 years)	
	Maxell-CR17450A - 2500 mAh EVE-CR17450 - 2400 mAh FDK-CR17450E-N - 2600 mAh	
Type of mounting:	Ceiling	
Radio link:	Yes	
Options with requirements:	Individual alarm indicator:	Yes
	Connection of external ancillary devices:	No
	Inter-connectable smoke alarm device:	Yes
	Alarm silence facility:	Yes
	Smoke alarm device for leisure accommodation vehicles:	No

placed on the market by

Hangzhou Hikvision Digital Technology Co., Ltd
No. 555 Qianmo Road, Binjiang District - 310052 HANGZHOU
China

and produced in the factory

**WIZMART TECHNOLOGY Inc. - Building B, 88 chang-yang road, Jiangbei investment pioneering park
305033 NINGBO, ZHEJIANG - China**

are submitted by the manufacturer to a factory production control (FPC) and to further testing of samples taken at the factory in accordance with a prescribes test plan,

The approved body, CNPP Cert., has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the FPC and performs the continuous surveillance, assessment and approval of the FPC.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance according to system 1 and the characteristics described in ZA annex of the standards EN 14604 : 2005/AC : 2008 were applied and that the product fulfils all prescribed requirements.

*This certificate was first issued on **13/11/2020** and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.*

On 13/11/2020


Amaury LEQUETTE
Manager of CNPP Cert.



CNPP Cert. certification body (NB 1116)
recognized by the security and insurance professionals
Route de la Chapelle Réanville - CD 64 - CS 22265 - F 27950 LA CHAPELLE-LONGUEVILLE
Tel. : +33 (0)2 32 53 63 63 - E.mail : certification@cnpp.com - www.cnpp.com

